

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-23-05-12-01

**Product:** Unilin laminate floor covering, 8 mm thickness, Class 32

**Producer:** Unilin BV Division Flooring  
Ooigemstraat 3  
8710 Wielsbeke  
Belgium

**Order:** Determination and classification of selected properties  
according to EN 14041:2004+AC:2005+AC:2006 (CE-labelling)

**Test Report:** 2723129

**Test Results:**

Property	Results	Declaration according to EN 14041:2004+AC:2005+AC:2006
Reaction to fire according to EN ISO 9239-1:2010 and EN ISO 11925-2:2020 Classification according to EN 13501-1:2018 - Critical heat flux - Smoke production	5,6 kW / m <sup>2</sup> 29 % x min	Reaction to fire class* C <sub>fi</sub> -s1
Slip resistance according to EN 13893:2002	μ = 0,39	DS
Formaldehyde emission according to EN 717-1:2004	0,01 ppm (264 h)	E1
Content of PCP according to CEN/TR 14823:2004	< LOQ	PCP ≤ 5 ppm
Thermal resistance according to EN 12667:2001	0,0545 (m <sup>2</sup> K)/W	0,055 (m <sup>2</sup> K)/W
Electrostatic behaviour according to EN 1815:2016	BV = 0,9 kV	Antistatic floor covering

\* Valid on wooden or mineral subfloor in end use application, using 2 mm underlay "UNISOUND"  
LOQ = Limit of Quantitation      BV = Body voltage

Dresden, 12/05/2023



*p.p. Andreas Heide*  
Head of laboratory

*p.p. Heide*  
Engineer in charge